

TANK VENT BRICK

Approved by the New York City Board of Standards and Appeals (Cal. No. 15-36 SA)

The **Tank Vent Brick** is designed as a terminal for vent lines from storage tanks when the line is run inside the building walls. Such lines are hidden from view and must be protected from damage or vandalism in a manner that does not infringe upon property lines. The face of the Tank Vent Brick is the same 2 1/8" x 8" x 3" measurement as a standard masonry brick and blends into all types of wall construction.

Tank Vent Bricks are made of a one-piece aluminum casting, weigh three pounds and are available with screwed connections to accept either 2" or 3" pipe.

Suggested Specifications

Fuel oil vent line, as required by NFPA 30 Flammable and Combustible Liquids Code and NFPA 31 Standard for the Installation of Oil-Burning Equipment, shall terminate in a one piece, cast aluminum **Tank Vent Brick**, which is to be an integral part of the outer face of the building wall. **Tank Vent Brick** shall be furnished by Preferred Utilities Mfg. Corp., Danbury, CT.



Ordering Information

Catalog Number	Size	Weight
13079	2"	3 lbs.
13080	3"	3 lbs.